

Anderson, Alan

From: Todd Beaver <ToddBeaver@RWU.ORG>
Sent: Thursday, March 29, 2018 1:24 PM
To: Anderson, Alan
Cc: David Staib; Cary Roth; Earl Rausch
Subject: AR0043397 3-28-18 rain event

Follow Up Flag: Follow up
Flag Status: Flagged

Mr. Anderson,

We began overflowing this morning 3/29/18 at 7:52 from continued rain over the equalization basin walls. We were only able to draw down our Equalization basin 6" from the previous overflow before flows exceeded our treatment capacity again. We are still overflowing and appears we will continue beyond business hours today. I wanted to comply with the 24 hour rule of notification so please accept this as notification we are having an overflow event. When the overflow is complete we will issue a notice and the total amount. We are sampling every 500,000 gallons per our SOP.

If you have any further questions or comments, please contact us.

Sincerely,

Todd Beaver, P.E.
Plant Manager
479-273-7378

