

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0043397 Discharge Number: 001 and 002
Facility: Rogers Pollution Control Facility
Address: 4300 S. Rainbow Road
City: Rogers State: AR Zip: 72758
Contact: Todd Beaver Phone: 479-273-7378

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
1/16/2024	Chlorine concentration		.31	.1 mg/L

We feel this problem was due to:

~~We believe our SO2 regulator froze due to low temps and could not supply sufficient dechlorination.~~

We plan on correcting the problem in this manner:

~~Ensuring our regulators stay dry so they can't freeze.~~

Time estimated that it will take to correct problem:

~~20 minutes~~

Sincerely,



Submitted By:

1-17-24
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)