

# Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: City of Rogers

NPDES Permit No.: AR0043397

Monitoring Period (Month/Year): 01 / 2022

No Sanitary Sewer Overflows This Monitoring Period

## REPORT CODE DESCRIPTIONS

Cause(s) of SSO	Environmental Impact	Action(s) Taken	Ultimate Discharge Location
C - Construction	EFK - Evidence of Fish Kill	EC - Environmental Cleanup	GR - Ground
EF - Equipment Failure	OEHC - Evidence of Human Contact	HC - Hydro Cleaned	CR - Creek / Stream / River (specify)
LF - Line Failure	OEEL - Evidence of Environmental Impact	HR - Hand Rodded	DI - Ditch
PF - Power Failure	RO - Roots	MR - Machine Rodded	DR - Drop Inlet
V - Vandalism	NEAH - No Evidence of Adverse Health or Environmental Impact	PN - Public Notification	PA - Paved Area
		EN - Referred to Engineering	CB - Contained in Building
		JV - Jet Vac	
		SL - Spread Line	
		DD - Disinfected and Deodorized	
		GP - Used Generator to Power Equipment	

Starting Location (Address, Intersection, or Manhole #)	Start Date of SSO	End Date of SSO	Estim. Volume (in gallons)	Cause(s) of SSO	Environmental Impact	Action(s) Taken	Discharge Location
1208 W. Geneva St., MH #11-81	01/01/22	01/02/22	1500	Wipes	NEAH	JV, HC, SL	Private Prop. - Yard
811 N. 7th St., SMH-005-039	01/19/22	01/19/22	500	RO	NEAH	HC, SL	Down Street 150 ft.
2850 W. Walnut, SMH 001-049	01/22/22	01/22/22	2500	D	NEAH	HC, SL	Ground -- Public Land

*[Handwritten Signature]*

Signature of Cognizant or Ranking Official Date  
02/22/22

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Mail together with DMR submission **NO LATER THAN THE 25th OF THE MONTH FOLLOWING THE MONITORING PERIOD** to:  
 ADEQ Office of Water Quality ❖ 5301 Northshore Drive ❖ North Little Rock, AR 72118