

Harbin, Danielle

From: Todd Beaver <toddbeaver@RWU.ORG>
Sent: Saturday, December 18, 2021 1:26 PM
To: SSOADEQ
Cc: Brent Dobler; David Staib
Subject: AR0043397 Overflow report at the plant 12/18/21

Please accept this email as our required 24 hour notification of an overflow at our treatment facility. This was due to rainfall of approximately 3.7" of rain in a single event. The EQ basin was empty at the beginning of the event. The plant began to overflow at 4:31 A.M. We are continuing to overflow, so I will update with a total overflow estimate on Monday. We are taking samples as per our Established SOP and will evaluate those samples per procedure. If you have any questions or need more information, please contact me.

Sincerely,

Todd Beaver, P.E.
Plant Manager
479-273-7378

*Please note: Our email domain has changed. My new email address is ToddBeaver@RWU.org



ROGERS WATER UTILITIES (RWU) CONFIDENTIALITY NOTICE - THIS ELECTRONIC MAIL TRANSMISSION AND ANY DOCUMENTS ACCOMPANYING IT MAY CONTAIN CONFIDENTIAL INFORMATION CONCERNING RWU AND ITS CUSTOMERS THAT IS PROTECTED FROM DISCLOSURE BY THE ARKANSAS FREEDOM OF INFORMATION ACT (FOIA), CODIFIED AT ARK CODE ANN. § 25-19-101 ET SEQ. AND OTHER APPLICABLE LAW. THE INFORMATION IS INTENDED ONLY FOR THE USE OF THE PERSON TO WHOM IT IS ADDRESSED. IF YOU HAVE RECEIVED THIS TRANSMISSION IN ERROR, PLEASE IMMEDIATELY NOTIFY THE SENDER TO ARRANGE FOR THE RETURN OF THE MESSAGE AND ANY ATTACHED DOCUMENTS. NOTHING IN THIS ELECTRONIC MAIL TRANSMISSION AND THE ACCOMPANY DOCUMENTS SHALL BE CONSTRUED AS A WAIVER, LIMIT, MODIFICATION, NULLIFICATION, OR ALTERATION OF THE TORT IMMUNITY AND OTHER RIGHTS AND IMMUNITIES GRANTED TO RWU, THE ROGERS WATERWORKS AND SEWER COMMISSION, AND THE CITY OF ROGERS, ARKANSAS PURSUANT TO ARK CODE ANN. § 21-9-301 AND OTHER APPLICABLE LAW.