

Kristen Graham (adpce.ad)

From: Todd Beaver <toddbeaver@RWU.ORG>
Sent: Thursday, March 9, 2023 8:05 AM
To: SSOADEQ
Cc: David Staib; Brent Dobler; Patrick Pruitt
Subject: ar0043397 EQ basin overflow

Please accept this email as our required 24-hour notification of an overflow at the treatment facility. On Mar 7th and 8th, we received 1.61 inches of rain on already saturated ground with our equalization basins still substantially full from the previous event. This event caused our Equalization tanks to overflow at 6:45 PM on Mar 8th. We will update the total overflow 3/10/23 when rain is out of the forecast. A correction to our previous report, our SOP is to sample every 500,000 estimated gallons rather than every MG.

Sincerely,

Todd Beaver, P.E.
Plant Manager
479-273-7378

***Please note: Our email domain has changed. My new email address is ToddBeaver@RWU.org**



ROGERS WATER UTILITIES (RWU) CONFIDENTIALITY NOTICE - THIS ELECTRONIC MAIL TRANSMISSION AND ANY DOCUMENTS ACCOMPANYING IT MAY CONTAIN CONFIDENTIAL INFORMATION CONCERNING RWU AND ITS CUSTOMERS THAT IS PROTECTED FROM DISCLOSURE BY THE ARKANSAS FREEDOM OF INFORMATION ACT (FOIA), CODIFIED AT ARK CODE ANN. § 25-19-101 ET SEQ. AND OTHER APPLICABLE LAW. THE INFORMATION IS INTENDED ONLY FOR THE USE OF THE PERSON TO WHOM IT IS ADDRESSED. IF YOU HAVE RECEIVED THIS TRANSMISSION IN ERROR, PLEASE IMMEDIATELY NOTIFY THE SENDER TO ARRANGE FOR THE RETURN OF THE MESSAGE AND ANY ATTACHED DOCUMENTS. NOTHING IN THIS ELECTRONIC MAIL TRANSMISSION AND THE ACCOMPANY DOCUMENTS SHALL BE CONSTRUED AS A WAIVER, LIMIT, MODIFICATION, NULLIFICATION, OR ALTERATION OF THE TORT IMMUNITY AND OTHER RIGHTS AND IMMUNITIES GRANTED TO RWU, THE ROGERS WATERWORKS AND SEWER COMMISSION, AND THE CITY OF ROGERS, ARKANSAS PURSUANT TO ARK CODE ANN. § 21-9-301 AND OTHER APPLICABLE LAW.