

# Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: City of Rogers

NPDES Permit No.: AR0043397

Monitoring Period (Month/Year): 02 / 2022

No Sanitary Sewer Overflows This Monitoring Period

REPORT CODE DESCRIPTIONS			
Cause(s) of SSO	Environmental Impact	Action(s) Taken	Ultimate Discharge Location
<b>C</b> - Construction	<b>EFK</b> - Evidence of Fish Kill	<b>EC</b> - Environmental Cleanup	<b>GR</b> - Ground
<b>D</b> - Debris	<b>OEHC</b> - Evidence of Human Contact	<b>JV</b> - Jet Vac	<b>CR</b> - Creek / Stream / River (specify)
<b>EF</b> - Equipment Failure	<b>OEEI</b> - Evidence of Environmental Impact	<b>SL</b> - Spread Lime	<b>DI</b> - Ditch
<b>LF</b> - Line Failure	<b>NEAH</b> - No Evidence of Adverse Health or Environmental Impact	<b>HR</b> - Hand Rodded	<b>DR</b> - Drop Inlet
<b>PF</b> - Power Failure		<b>MR</b> - Machine Rodded	<b>PA</b> - Paved Area
<b>V</b> - Vandalism		<b>PN</b> - Public Notification	<b>CB</b> - Contained in Building
		<b>EN</b> - Referred to Engineering	
		<b>GP</b> - Used Generator to Power Equipment	

Starting Location (Address, Intersection, or Manhole #)	End Date of SSO	Start Date of SSO	Estim. Volume (in gallons)	Cause(s) of SSO	Environmental Impact	Action(s) Taken	Discharge Location
422 W. Elm St., SMH-007-097	02/10/22	02/10/22	2,000	G	NEAH	JV, HC, SL	Street, storm drain

Signature of Cognizant or Ranking Official \_\_\_\_\_ Date 03/10/22

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Mail together with DMR submission **NO LATER THAN THE 25th OF THE MONTH FOLLOWING THE MONITORING PERIOD** to:  
 ADEQ Office of Water Quality ♦ 5301 Northshore Drive ♦ North Little Rock, AR 72118