

ROGERS POLLUTION CONTROL FACILITY

"Serving Rogers - Protecting Our Environment"

Allen Anderson
NPDES Enforcement Branch
5301 Northshore Drive
North Little Rock, AR. 72118

August 4, 2016

Permit Number: AR0043397

Dear Mr. Anderson,

On July 28th a full ton Cl₂ cylinder was added to our dual feed scaling system and our Superior auto switchover gas chlorinator was installed and tested for leaks following the appropriate SOP steps. During this process the operations staff failed to notice a lead washer wedged in the tank valve that the regulator was attached too. At approximately 3:00 pm Friday afternoon, the original tank emptied calling for feed to begin from the full tank that was waiting on standby. The equipment functioned properly, but because of the lead washer in the valve no chlorination occurred from this time until Monday morning at approximately 9:00 am. At 9:00 am the problem was discovered and corrected immediately allowing chlorination to continue.

Our SOP has been updated to include that an inspection is done on the tank valve before our regulators are attached. We will also be performing a longer test run on a new regulator hookup to make sure that our system vacuum is operating in the proper range.

Yours truly,

A handwritten signature in black ink, appearing to read "David Staib", is written over a white background.

David Staib

RWU Operations Supervisor


ROGERS POLLUTION CONTROL FACILITY
4300 RAINBOW ROAD
ROGERS, ARKANSAS 72758-1440



7016 0910 0001 0096 4903

Allen Anderson
NPDES Enforcement Branch
5301 Northshore Drive
North Little Rock, AR.72118

ST AR P&DF
AR 727 2 T
AUG 2016 PM



U.S. POSTAGE
PAID
BENTONVILLE, AR
72712
AUG 04 16
AMOUNT
\$3.77
R2304M11213-05



72118



1000

7211845328

