

Sanitary Sewer Overflow Monthly Report

City of Rogers

AR0043397

Reporting Period:

May 2012

No Sanitary Sewer Overflow This Monitoring Period

Summary Report Code Descriptions				
Cause(s) of SSO		SSO Impact	Actions Taken	Ultimate Discharge Location
CO - Construction	D - Debris	NEAH - No Evidence of Adverse Health or Environmental Impact	WO - Work Order	CR - Creek/Stream/River (please specify)
E - Equipment Failure	G - Grease		EC - Environmental Cleanup	DI - Ditch
HC - Hydro Clean	LF - Line Failure/Break	OEAH - Observed or Evidence of Human Contact	HC - Hydro Clean	DR - Drop Inlet
R - Rainfall	RG - Roots & Grease		HR - Hand Rodded	GR - Ground Surface
RO - Roots	V - Vandalism	EFK - Evidence of Fish Kill	EN - Referred to Engineering	PA - Paved Area
			PN - Public Notification	CB - Contained in Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (gallons)	Cause of SSO	Environ. Impact	Action(s) Taken to Address SSO	Ultimate Discharge Location
813 N. 28th Street	1-485	5/5/2012	5/5/2012	<100	RO	NEAH	HC/EC	GR
Lift station(Garrett road)	NA	5/14/2012	5/14/2012	1000	E	NEAH	EC	CR/Stream

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."



 Signature of Cognizant or Ranking Official

June 13, 2012
 Date

720 721 72114S N3--98

PSRT FIRST-CLASS MAIL
US POSTAGE PAID
Fayetteville, AR
PERMIT 986




4059120619-102415

3

RETURN SERVICE REQUESTED

72118



FROM:

ROGERS POLLUTION CONTROL FACILITY
4300 RAINBOW ROAD
ROGERS, AR 72758-1440

TO:

NPDES ENFORCEMENT SECTION
WATER DIVISION
A.D.E.Q.
5301 Northshore Drive
North Little Rock, AR 72118-5317