



December 4, 2014

Russell Thomas, Superintendent
City of Magnolia
P.O. Box 666
Magnolia, AR 71754-0666

RE: NPDES Permit No. AR0043613, AFIN 14-00059
Effluent Violations

Dear Mr. Thomas:

The Department has conducted a file review of the above referenced permit and determined your facility has experienced twenty eight (28) effluent violations from December 1, 2011 through October 30, 2014. Attached is a list of effluent violations that have occurred for your review.

Additionally, the City of Magnolia has reported 19 Sanitary Sewer Overflows totaling over 4,000 gallons in the review period. A detailed list of the overflows has been included with this letter. Sanitary Sewer Overflows are an unpermitted discharge and the Department expects the City of Magnolia to work towards eliminating them.

Please submit a report/plan detailing the corrective actions that you are taking or will take to achieve compliance with the terms of the above mentioned permit. The report should include a timeline for compliance. Please submit this report for review by **January 9, 2015**.

Failure to remain in compliance with the effluent limitations set forth in your permit violates Part I, Section A of your permit and may result in enforcement action that will include the assessment of a civil penalty.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0636 or you may e-mail me at porterg@adeq.state.ar.us.

Sincerely,

Gina Porter
Enforcement Analyst
Water Division Enforcement Branch

**AR0043613 - MAGNOLIA, CITY OF-BIG
CREEK WWTP / Major POTW - Effective:
01/01/2011**

[illegible][illegible][illegible]

**AR0043613 - MAGNOLIA, CITY OF-BIG
CREEK WWTP / Major POTW - Effective:
01/01/2011**

[illegible][illegible]

**AR0043613 - MAGNOLIA, CITY OF-BIG
CREEK WWTP / Major POTW - Effective:
01/01/2011**

AR0043613 - MAGNOLIA, CITY OF-BIG
CREEK WWTP / Major POTW - Effective:
01/01/2011

Discharge Number	Parameter Description	Violation Type	Outfall	Number of DMR Effluent Violations
001-A	BOD, carbonaceous, 05 day, 20 C	Numeric Vio	001	4
001-A	Chlorine, total residual	Numeric Vio		2
001-A	Coliform, fecal general	Numeric Vio		12
001-A	Nitrogen, ammonia total [as N]	Numeric Vio		8
001-A	pH	Numeric Vio		2
			001	28
			Sum:	28