

June 22, 2011

Russell Thomas, Superintendent City of Magnolia P.O. Box 666 Magnolia, AR 71754-0666

RE: NPDES Permit No. AR0043613, AFIN 14-00059

Dear Mr. Thomas:

A review of the NPDES file for the City of Magnolia for the period of April 1, 2011 thru April 30, 2011 reveals the following compliance issue:

The facility reported 4 violations of Part I, Section A. of NPDES Permit No.: AR0043613. The effluent violations reported on the DMR are as follows:

DMR End Date	Discharge	Parameter	Reported	Permit
			Value	Limit
04/30/2011	001A	Nitrogen, ammonia total (as N) (MO AVG, lb/d)	55.29	60
04/30/2011	001A	Nitrogen, ammonia total (as N) (MO AVG, mg/L)	6.88	2.4
04/30/2011	001A	Nitrogen, ammonia total (as N) (7 DA AVG, mg/L)	13.9	6.1
04/30/2011	001A	Coliform, fecal general (7 DA GEO, #/100mL)	796	400

The Department assumes that the City of Magnolia continues to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0635, or you may e-mail me at anderson@adeq.state.ar.us.

Sincerely,

Alan Anderson

Enforcement Analyst

Water Division / Enforcement Branch

Alan anderson