



ARKANSAS

ENERGY & ENVIRONMENT

March 4, 2021

Honorable Parnell Vann
Mayor, City of Magnolia
P.O. Box 666
Magnolia, AR 71754

email: mwws@sbcglobal.net

RE: NPDES Permit Number AR0043613, AFIN 14-00059
Permitted Effluent Limitation Violations

Dear Mayor Vann,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility revealed the following compliance issues:

The facility has reported 4 violations of Part I, Section A of NPDES Permit No. AR0043613 during the review period. DEQ requires the City of Magnolia to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0664, or you may e-mail me at Sarah.Pierce@adeq.state.ar.us.

Sincerely,

Sarah Pierce
Enforcement Analyst
Office of Water Quality, Enforcement Branch

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio	Violation Code
08/31/2020	001-A	Nitrogen, ammonia total [as N], MO AVG, mg/L	2.4	3.96	65%	E90
08/31/2020	001-A	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	4.8	6.86	43%	E90
03/31/2020	001-A	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	10.2	10.5	3%	E90
10/31/2019	001-A	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	4.8	6.34	32%	E90