

Kristen Graham (adpce.ad)

From: Kristen Graham (adpce.ad)
Sent: Monday, May 8, 2023 8:54 AM
To: 'mayor@magnolia-ar.com'
Subject: Effluent Violations Warning Email
Attachments: AR0043613 Magnolia Warning Letter.pdf

Good morning,

Please review the attached document detailing the effluent violations for the period of March 01, 2022 – March 31, 2023. Continued violations may result in formal enforcement action.

No further action is needed at this time.

Thank you,

KRISTEN GRAHAM

Compliance Analyst | 501.682.0758

Office of Water Quality | Enforcement Branch

Arkansas Division of Environmental Quality



ARKANSAS
ENERGY & ENVIRONMENT



ARKANSAS

ENERGY & ENVIRONMENT

May 8, 2023

Parnell Vann, Mayor
City of Magnolia – Big Creek
P.O. Box 666
Magnolia, AR, 71754

email: mayor@magnolia-ar.com

**RE: Permit Number: AR0043613, AFIN 14-00059
Effluent Violation Warning Letter**

Dear Mayor Brick,

A review of the Permit file for the above mentioned facility for the period of March 01, 2022 through March 31, 2023 reveals the following compliance issues:

The facility has reported **Eight (8) effluent violations** of Part I, Section A of Permit No. AR0043613:

DMR End Date	Discharge Number	Parameter Description	Reported DMR Value	Permit Limit	Vio %
05/31/2022	001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	4.93	4.8	3%
06/30/2022	001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	5	4.8	4%
07/31/2022	001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	6.5	4.8	35%
09/30/2022	001-A	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	4.01	2.4	67%
09/30/2022	001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	9.46	4.8	97%
10/31/2022	001-A	Nitrogen, ammonia total [as N] (MO AVG, lb/d)	54.39	50	9%
10/31/2022	001-A	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	6.67	2.4	178%
10/31/2022	001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	10.3	4.8	115%

Non-compliance reports (NCRs) with corrective actions were received by the Division for all of the above listed violations.

Any violation of your Permit is subject to further enforcement action by this Division, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0758, or you may e-mail me at Kristen.Graham@adeq.state.ar.us.

Sincerely,

A handwritten signature in blue ink that reads "Kristen Graham". The signature is written in a cursive style with a long horizontal line extending to the right.

Kristen Graham
Enforcement Analyst, DEQ, OWQ
5301 Northshore Drive, North Little Rock, AR 72118

CC: Russell Thomas, Superintendent, mwws@sbcglobal.net