

**From:** [Wastewater System Magnolia](#)  
**To:** [Porter, Gina](#)  
**Subject:** City of Magnolia-Big Creek WWTP Permit No. AR0043613 AFIN # 14-00059 Equalization pond levee breach  
**Date:** Friday, March 13, 2015 1:33:37 PM

---

Miss.Porter

Per our conversation on the phone I am sending you a e-mail notification that our equalization pond has started to breach our levee. Big Creek is also backed up and threatening to breach our pond.

We have not utilized our pond for equalization in over a week or longer. We have contended with the run off of melting snow and ice along with over six inches of rain.

We are currently pumping our equalization pond back into our treatment plant. We are also placing sand bags in the area of the pond levee where the water is running over in an attempt to stop it.

If you have any questions feel free in contacting me at 870-904-1694

Russell W. Thomas, Manager/Supt.  
City of Magnolia Big-Creek WWTP  
AR0043613  
AFIN# 1400059