



ARKANSAS  
Department of Environmental Quality

October 1, 2012

Russell Thomas, Superintendent  
City of Magnolia  
P.O. Box 666  
Magnolia, AR 71754-0666

RE: NPDES Permit No. AR0043613, AFIN 14-00059

Dear Mr. Thomas:

A review of the NPDES file for the City of Magnolia for the period of May 1, 2012 thru July 31, 2012 reveals the following compliance issue:

The facility reported 4 violations of Part I, Section A. of NPDES Permit No.: AR0043613. The effluent violations reported are as follows:

DMR End Date	Discharge	Parameter	Reported Value	Permit Limit
05/31/12	001A	Coliform, fecal general (30 DA GEO, #/100mL)	230	200
05/31/12	001A	Coliform, fecal general (7 DA GEO, #/100mL)	800	400
06/30/12	001A	Coliform, fecal general (7 DA GEO, #/100mL)	800	400
07/31/12	001A	Coliform, fecal general (7 DA GEO, #/100mL)	550	400

The Department expects the City of Magnolia to continue to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0635, or you may e-mail me at [anderson@adeq.state.ar.us](mailto:anderson@adeq.state.ar.us).

Sincerely,

Alan Anderson  
Enforcement Analyst  
Water Division / Enforcement Branch