

Kristen Graham (adpce.ad)

From: Kristen Graham (adpce.ad)
Sent: Wednesday, December 14, 2022 11:38 AM
To: 'mwws@sbcglobal.net'
Subject: NCR Correction Needed
Attachments: October2022Noncompliance.docx

Good afternoon,

Upon review, NetDMR has flagged an error in your submission for Magnolia Big Creek WWTP (AR0043613), October 2022 (001-A). The value for Ammonia Nitrogen is outside of the permit limits. I see that you submitted a NCR along with the submission, however the "We plan on correcting the problem in this manner" field has been left blank. I do see that you have included "As soon as the contractors finish and depart the plant," however this a timeframe to resolve the issue, not a corrective action.

I have attached the document in question. Please correct this and email it back to me as soon as possible.

Thank you,

KRISTEN GRAHAM

Compliance Analyst | 501.682.0624
Office of Water Quality | Enforcement Branch
Arkansas Division of Environmental Quality



ARKANSAS
ENERGY & ENVIRONMENT