

NON-COMPLIANCE REPORT

February 21, 2023

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 North Shore Drive
North Little Rock, AR 72118

RE: NPDES Permit No. AR0043613 **AFIN No.** 14-00059 **Discharge Number:** 001

Facility: City of Magnolia-Big Creek WWTP

Physical Address: 72 Columbia Road 300 Magnolia, AR 71753

Mailing Address: P.O. Box 666 Magnolia, AR 71754-0666

Contact: Russell Thomas **Phone:** 870-234-2955 **Fax:** 870-234-2203

Email: mwws@sbcglobal.net

Date of Non-compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
01/25/2023	Total Residual Chlorine		0.03 mg/l	0.011 mg/l

We feel like this problem was due to:

We were manually chlorinated due to high flow and did not adjust chlorine feed in time when flow dropped out.

We plan on correcting the problem in this manner:

We placed chemical feed machine back in automatic feed mode.

Time estimated that it will take to correct problem.

We corrected the the problem as soon as we realized what had happened.

Sincerely

Russell W. Thomas

Russell W. Thomas

___02/21/2023___
Date