

## NON-COMPLIANCE REPORT

August 21, 2017, 2017

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 North Shore Drive  
North Little Rock, AR 72118

**RE: NPDES Permit No.** AR0043613    **AFIN No.** 14-00059    **Discharge Number:** 001

**Facility:** City of Magnolia-Big Creek WWTP

**Physical Address:** 72 Columbia Road 300 Magnolia, AR 71753

**Mailing Address:** P.O. Box 666 Magnolia, AR 71754-0666

**Contact:** Russell Thomas    **Phone:** 870-234-2955    **Fax:** 870-234-2203

**Email:** [mwws@sbcglobal.net](mailto:mwws@sbcglobal.net)

Date of Non-compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
06/27/2017	Fecal Coliform		843 col / 100 mil	400 col / 100 mil
06/27/2017	TSS		22.7 mg/l	22.5 mgl

**We feel like this problem was due to:**

We have opened the equalization pond to the plant in a effort to drain pond, water coming from the pond has a high amount of algae in it.

**We plan on correcting the problem in this manner:**

To comply with the conditions set forth by ADEQ's consent order we are draining our equalization pond to the plant to get it low enough to begin cleaning it out.

**Time estimated that it will take to correct problem:**

As soon as the algae clears up.

The Violations listed are from the last week of June, since July 1<sup>st</sup> fell on Saturday we are required to include the last week of June in our calculation for July's test results.

Sincerely

---

Russell W. Thomas

---

08/21/2017  
Date