

NON-COMPLIANCE REPORT

July 21, 2022

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 North Shore Drive
North Little Rock, AR 72118

RE: NPDES Permit No. AR0043613 **AFIN No.** 14-00059 **Discharge Number:** 001

Facility: City of Magnolia-Big Creek WWTP

Physical Address: 72 Columbia Road 300 Magnolia, AR 71753

Mailing Address: P.O. Box 666 Magnolia, AR 71754-0666

Contact: Russell Thomas **Phone:** 870-234-2955 **Fax:** 870-234-2203

Email: mwws@sbcglobal.net

Date of Non-compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
06/27/2022	Ammonia Nitrogen		5.0 mg/l. 7 day Avg. Daily Max	4.8 mg/l, 7day AVG. Daily Max

We feel like this problem was due to;

We lost the mechanical drive on the clarifier that was in service so we were in the process of filling up the clarifier that the contractor just finished repairing.

We plan on correcting the problem in this manner:

**We have ordered the mechanical drive for clarifier # 2 and still waiting on parts for Clarifier # 3
Clarifier # 1 is on line at this time.**

Time estimated that it will take to correct problem.

Should have corrected the problem by placing Clarifier # 1 in service.

Sincerely

Russell W. Thomas

Russell W. Thomas

____07/21/2022_____
Date

NON-COMPLIANCE REPORT