

NON-COMPLIANCE REPORT

June 21, 2022

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 North Shore Drive
North Little Rock, AR 72118

RE: NPDES Permit No. AR0043613 **AFIN No.** 14-00059 **Discharge Number:** 001

Facility: City of Magnolia-Big Creek WWTP

Physical Address: 72 Columbia Road 300 Magnolia, AR 71753

Mailing Address: P.O. Box 666 Magnolia, AR 71754-0666

Contact: Russell Thomas **Phone:** 870-234-2955 **Fax:** 870-234-2203

Email: mwws@sbcglobal.net

Date of Non-compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
05/02/2022	Ammonia Nitrogen		4.93 mg/l. 7 day Avg. Daily Max	4.8 mg/l, 7day AVG. Daily Max

We feel like this problem was due to;

Excessive flow due to I & I.

We plan on correcting the problem in this manner:

Continual smoke testing and Manhole rehab.

Time estimated that it will take to correct problem

Sincerely

Russell W. Thomas

Russell W. Thomas

____06/21/2022____

Date