

## NON-COMPLIANCE REPORT

May 23, 2017

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 North Shore Drive  
North Little Rock, AR 72118

**RE: NPDES Permit No.** AR0043613    **AFIN No.** 14-00059    **Discharge Number:** 001

**Facility:** City of Magnolia-Big Creek WWTP

**Physical Address:** 72 Columbia Road 300 Magnolia, AR 71753

**Mailing Address:** P.O. Box 666 Magnolia, AR 71754-0666

**Contact:** Russell Thomas    **Phone:** 870-234-2955    **Fax:** 870-234-2203

**Email:** [mwws@sbcglobal.net](mailto:mwws@sbcglobal.net)

Date of Non-compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
04/18/2017	Fecal Coliform		800 col / 100 mil	400 col / 100 mil

**We feel like this problem was due to:**

The filter in the chlorine header stopped up and was not feeding the right amount of Chlorine.

**We plan on correcting the problem in this manner:**

We changed out the filter as soon as we found it.

**Time estimated that it will take to correct problem:**

immediately.

Sincerely

---

Russell W. Thomas

05/23/2017  
Date