

NON-COMPLIANCE REPORT

May 21, 2018

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 North Shore Drive
North Little Rock, AR 72118

RE: NPDES Permit No. AR0043613 **AFIN No.** 14-00059 **Discharge Number:** 001

Facility: City of Magnolia-Big Creek WWTP

Physical Address: 72 Columbia Road 300 Magnolia, AR 71753

Mailing Address: P.O. Box 666 Magnolia, AR 71754-0666

Contact: Russell Thomas **Phone:** 870-234-2955 **Fax:** 870-234-2203

Email: mwws@sbcglobal.net

Date of Non-compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
04/30/2018	pH		5.77 s.u.	6.0 s.u. – 9.0 s.u.

We feel like this problem was due to;

Excessive rainfall (I & I) and taking water in from the equalization pond.

We plan on correcting the problem in this manner:

Contract for automatic pH adjustment equipment has been awarded.

This system will monitor and adjust our pH as needed.

Time estimated that it will take to correct problem:

Installation should begin within the next sixty days.

Sincerely

Russell W. Thomas

Russell W. Thomas

05/21/2018

Date