

NON-COMPLIANCE REPORT

September 20, 2017

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 North Shore Drive
North Little Rock, AR 72118

RE: NPDES Permit No. AR0043613 **AFIN No.** 14-00059 **Discharge Number:** 001

Facility: City of Magnolia-Big Creek WWTP

Physical Address: 72 Columbia Road 300 Magnolia, AR 71753

Mailing Address: P.O. Box 666 Magnolia, AR 71754-0666

Contact: Russell Thomas **Phone:** 870-234-2955 **Fax:** 870-234-2203

Email: mwws@sbcglobal.net

Date of Non-compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
08/22/2017	Total Residual Chlorine		0.16 mg/l	0.10 mg/l
08/29/2017	Total Residual Chlorine		0.30 mg/l	0.10 mg/l

We feel like this problem was due to:

Dirty Sulfur dioxide tank stopping up and not feeding gas. Tank in question still has 1,069 pounds of chemical in it that we cannot get out. Chemicals from this supplier has been stopping up our feed manifolds.

We plan on correcting the problem in this manner:

We have switched chemical suppliers, since then we have not had any problems with feeding chemicals

Time estimated that it will take to correct problem:

Problem has been corrected.

Sincerely

Russell W. Thomas

09/20/2017
Date