

## NON-COMPLIANCE REPORT

January 23, 2019

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 North Shore Drive  
North Little Rock, AR 72118

**RE: NPDES Permit No.** AR0043613    **AFIN No.** 14-00059    **Discharge Number:** 001

**Facility:** City of Magnolia-Big Creek WWTP

**Physical Address:** 72 Columbia Road 300 Magnolia, AR 71753

**Mailing Address:** P.O. Box 666 Magnolia, AR 71754-0666

**Contact:** Russell Thomas    **Phone:** 870-234-2955    **Fax:** 870-234-2203

**Email:** [mwws@sbcglobal.net](mailto:mwws@sbcglobal.net)

Date of Non-compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
12/09/2018	pH	-	5.50	6.0 s.u – 9.0 s.u.
12/09/2019	TRC	-	0.21	<0.1 mg/l (inst.Max)

**We feel like this problem was due to;**

ph was probably due to excessive rainwater in plant flow.

TRC due to over feeding cl2 during high flow.

**We plan on correcting the problem in this manner:**

We are still smoke testing and performing manholes to identify inflow source.

**Time estimated that it will take to correct problem:**

AS soon as we identify source.

Sincerely

Russell W. Thomas

\_\_\_\_\_  
Russell W. Thomas

\_\_\_\_01/23/2019\_\_\_\_\_  
Date