

NON-COMPLIANCE REPORT

March 20, 2018

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 North Shore Drive
North Little Rock, AR 72118

RE: NPDES Permit No. AR0043613 **AFIN No.** 14-00059 **Discharge Number:** 001

Facility: City of Magnolia-Big Creek WWTP

Physical Address: 72 Columbia Road 300 Magnolia, AR 71753

Mailing Address: P.O. Box 666 Magnolia, AR 71754-0666

Contact: Russell Thomas **Phone:** 870-234-2955 **Fax:** 870-234-2203

Email: mwws@sbcglobal.net

Date of Non-compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
02/26/2018	pH		5.7 s.u.	6.0 s.u. – 9.0 s.u.

We feel like this problem was due to;

Excessive rainfall (I & I) and taking water in from the equalization pond.

We plan on correcting the problem in this manner:

We will be going out to bid for an automatic caustic feed system on March 27, 2018.

This system will monitor and adjust our pH as needed.

Time estimated that it will take to correct problem:

Ninety days from the time the contract is awarded.

Sincerely

Russell W. Thomas

Russell W. Thomas

03/20/2018

Date