

NON-COMPLIANCE REPORT

August 15, 2018

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 North Shore Drive
North Little Rock, AR 72118

RE: NPDES Permit No. AR0043613 **AFIN No.** 14-00059 **Discharge Number:** 001

Facility: City of Magnolia-Big Creek WWTP

Physical Address: 72 Columbia Road 300 Magnolia, AR 71753

Mailing Address: P.O. Box 666 Magnolia, AR 71754-0666

Contact: Russell Thomas **Phone:** 870-234-2955 **Fax:** 870-234-2203

Email: mwws@sbcglobal.net

Date of Non-compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
07/23/2018	Fecal Coliform		800/1000ml	200 400/1000ml

We feel like this problem was due to;

Do not know, we had split the sample between two labs. One lab result was 31 / 1000ml the other lab result was 800 / 1000ml

We plan on correcting the problem in this manner:

No malfunctions in the chemical system had been reported that day.

Will observe both labs while they are collecting the samples to insure proper sampling technique is performed.

Time estimated that it will take to correct problem:

Immediately.

Sincerely

Russell W. Thomas

Russell W. Thomas

08/15/2018
Date