

## NON-COMPLIANCE REPORT

November 21, 2017

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 North Shore Drive  
North Little Rock, AR 72118

**RE: NPDES Permit No.** AR0043613    **AFIN No.** 14-00059    **Discharge Number:** 001

**Facility:** City of Magnolia-Big Creek WWTP

**Physical Address:** 72 Columbia Road 300 Magnolia, AR 71753

**Mailing Address:** P.O. Box 666 Magnolia, AR 71754-0666

**Contact:** Russell Thomas    **Phone:** 870-234-2955    **Fax:** 870-234-2203

**Email:** [mwws@sbcglobal.net](mailto:mwws@sbcglobal.net)

Date of Non-compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
10/24/2017	TSS 7 day avg.		26.70	15 mg/l
10/24/2017	CBOD monthly avg.		15.10	10 mg/l
10/31/2017	CBOD 7 day avg.		23.0	15 mg/l

**We feel like this problem was due to:**

We are taking water in from the equalization pond in the attempt to drain it as set forth by our consent order.

**We plan on correcting the problem in this manner:**

As soon as the pond is drained the problem will correct its self

**Time estimated that it will take to correct problem:**

?

Sincerely

---

Russell W. Thomas

---

09/20/2017

Date