

NON-COMPLIANCE REPORT

January 18, 2018

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 North Shore Drive  
North Little Rock, AR 72118

**RE: NPDES Permit No.** AR0043613    **AFIN No.** 14-00059    **Discharge Number:** 001

**Facility:** City of Magnolia-Big Creek WWTP

**Physical Address:** 72 Columbia Road 300 Magnolia, AR 71753

**Mailing Address:** P.O. Box 666 Magnolia, AR 71754-0666

**Contact:** Russell Thomas    **Phone:** 870-234-2955    **Fax:** 870-234-2203

**Email:** [mwws@sbcglobal.net](mailto:mwws@sbcglobal.net)

Date of Non-compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
12/28/2017	TSS 7 Day Avg.		42.0 mg/l	22 mg/l

**We feel like this problem was due to:**

High flow and we started taking water again stabilization pond in the attempt to drain it as set forth by our consent order.

**We plan on correcting the problem in this manner:**

We are still in process of smoke testing our line so we can identify the source of infiltration.

We have gone out to bid for the cleaning out of our stabilization pond .

**Time estimated that it will take to correct problem:**

Immediately.

Sincerely

\_\_\_\_\_  
Russell W. Thomas

\_\_\_\_\_  
01/18/2018

Date

## NON-COMPLIANCE REPORT