

NON-COMPLIANCE REPORT

June 13, 2018

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 North Shore Drive
North Little Rock, AR 72118

RE: NPDES Permit No. AR0043613 **AFIN No.** 14-00059 **Discharge Number:** 001

Facility: City of Magnolia-Big Creek WWTP

Physical Address: 72 Columbia Road 300 Magnolia, AR 71753

Mailing Address: P.O. Box 666 Magnolia, AR 71754-0666

Contact: Russell Thomas **Phone:** 870-234-2955 **Fax:** 870-234-2203

Email: mwws@sbcglobal.net

| Date of Non-compliance | Parameter Exceeded | Quantity or Loading | Quality or Concentration | Permit Limits |
|------------------------|--------------------|---------------------|--------------------------|---------------|
| 05/14/2018 | TRC | 0.37 mg/l | | <0.1 mg/l |
| | | | | |
| | | | | |
| | | | | |

We feel like this problem was due to:

The filter in the Sulfur Dioxide header stopped up and was not feeding the right amount of Sulfur Dioxide to de-chlorinate properly.

We plan on correcting the problem in this manner:

We changed out the filter as soon as we found it.

Time estimated that it will take to correct problem:

Immediately.

Sincerely

Russell W. Thomas

06/13/2018
Date