

NON-COMPLIANCE REPORT

December 13, 2017

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 North Shore Drive  
North Little Rock, AR 72118

**RE: NPDES Permit No.** AR0043613    **AFIN No.** 14-00059    **Discharge Number:** 001

**Facility:** City of Magnolia-Big Creek WWTP

**Physical Address:** 72 Columbia Road 300 Magnolia, AR 71753

**Mailing Address:** P.O. Box 666 Magnolia, AR 71754-0666

**Contact:** Russell Thomas    **Phone:** 870-234-2955    **Fax:** 870-234-2203

**Email:** [mwws@sbcglobal.net](mailto:mwws@sbcglobal.net)

Date of Non-compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
11/07/2017	TSS 7 Day Avg.		43.6 mg/l	22 mg/l
11/14/2017	TSS monthly avg		15.10 mg/l	15 mg/l
11/07/2017	CBOD 7 day avg.		23.0 mg/l	15 mg/l

**We feel like this problem was due to:**

We were taking water in from the equalization pond in the attempt to drain it as set forth by our consent order.

**We plan on correcting the problem in this manner:**

We have quit draining the equalization pond into the plant

**Time estimated that it will take to correct problem:**

Immediately.

Sincerely

\_\_\_\_\_  
Russell W. Thomas

\_\_\_\_\_  
12/14/2017  
Date