

NON-COMPLIANCE REPORT

December 17, 2018

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 North Shore Drive  
North Little Rock, AR 72118

**RE: NPDES Permit No.** AR0043613    **AFIN No.** 14-00059    **Discharge Number:** 001

**Facility:** City of Magnolia-Big Creek WWTP

**Physical Address:** 72 Columbia Road 300 Magnolia, AR 71753

**Mailing Address:** P.O. Box 666 Magnolia, AR 71754-0666

**Contact:** Russell Thomas    **Phone:** 870-234-2955    **Fax:** 870-234-2203

**Email:** [mwws@sbcglobal.net](mailto:mwws@sbcglobal.net)

Date of Non-compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
11/12/2018	TSS	807.31		313 lbs/day

**We feel like this problem was due to;**

High flow due to rainfall and bringing in water to the plant from equalization pond.

**We plan on correcting the problem in this manner:**

We are still smoke testing and performing manholes to identify inflow source.

**Time estimated that it will take to correct problem:**

AS soon as we identify source.

Sincerely

Russell W. Thomas

\_\_\_\_\_  
Russell W. Thomas

\_\_\_\_\_  
12/17/2018  
Date