

## Taylor, Bailey

---

**From:** Andy Franks <afranks@alfranksengineering.com>  
**Sent:** Tuesday, December 18, 2018 7:55 AM  
**To:** Taylor, Bailey  
**Cc:** Parnell Vann; Magnolia Wastewater System  
**Subject:** Re: Compliance Extension Request

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

Bailey,

The results of the smoke testing revealed primarily service line clean-out issues which were addressed as the smoke testing was taking place.

Two areas of necessary line replacement were also identified. The city plans to have these lines replaced and back in operation by the July 1, 2019.

Andy

**From:** Taylor, Bailey  
**Sent:** Thursday, December 13, 2018 1:23 PM  
**To:** Andy Franks  
**Cc:** Parnell Vann ; Magnolia Wastewater System  
**Subject:** RE: Compliance Extension Request

Mr. Franks,

Please clarify the final compliance date for the SSES plan. You referenced that a Capital Improvement Projects plan will be submitted upon completion of the smoke testing; when is the anticipated final completion date in that plan?

Thanks,

*Bailey Taylor*  
Enforcement Coordinator  
Office of Water Quality  
Arkansas Department of Environmental Quality  
501-682-0639

---

**From:** Andy Franks [<mailto:afranks@alfranksengineering.com>]  
**Sent:** Thursday, December 06, 2018 12:56 PM  
**To:** Taylor, Bailey; Parnell Vann; Magnolia Wastewater System  
**Subject:** Compliance Extension Request

Bailey,

Please see attachment.  
Original is in the mail to you.

**Anthony L. (Andy) Franks, P.E.**  
**President/CEO**



118 East Broad Street – Texarkana, AR  
101 West Main, Ste. 413 – El Dorado, AR  
**Texarkana, AR – (870) 216-1906**  
**Fax Texarkana, AR – (870) 216-1907**  
**El Dorado, AR – (870) 444-5160**  
**Fax El Dorado, AR – (870) 444-5161**  
[www.alfranksengineering.com](http://www.alfranksengineering.com)