

Bio-Analytical Laboratories (BAL)
ADEQ Certificate #88-0630
Project X5780

Bio-Analytical Laboratories' Executive Summary

Permittee: Magnolia Wastewater System
P.O. Box 666
Magnolia, AR 71753

Project #: X5780

Outfall: 001 (treated municipal wastewater)

Permit #: AR0043613/ AFIN #14-00059

Contact: Russell Thomas

Dates: June 23 - 30, 2015

Test Type: Chronic Static Renewal Survival and Reproduction Test using *Ceriodaphnia dubia* (EPA Method 1002.0)
Chronic Static Renewal Survival and Growth Test using *Pimephales promelas* (EPA Method 1000.0)

Results:

For *Ceriodaphnia dubia*:

1. If the NOEC for survival is less than the critical dilution (100.0%), enter a "1"; otherwise, enter a "0" for Parameter TLP3B - 0 -Pass ✓
2. If the NOEC for reproduction is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter TGP3B - 0 - Pass ✓
3. Report the NOEC value for survival, Parameter TOP3B - 100.0%. ✓
4. Report the NOEC value for reproduction, Parameter TPP3B - 100.0%. ✓
5. Report the largest % coefficient of variation between the control and the critical dilution, Parameter TQP3B - 16.23%. ✓


For *Pimephales promelas*:

1. If the NOEC for survival is less than the critical dilution (100.0%), enter a "1"; otherwise, enter a "0" for Parameter TLP6C - 0 -Pass ✓
2. If the NOEC for growth is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter TGP6C - 0 -Pass ✓
3. Report the NOEC value for survival, Parameter TOP6C - 100.0%.
4. Report the NOEC value for reproduction, Parameter TPP6C - 100.0%.
5. Report the largest % coefficient of variation between the control and the critical dilution, Parameter TQP6C - 21.94%.

This report contains a total of 43 pages, including this page. The results contained within pertains only to the samples listed on the chain of custody documents in Appendix A. The information meets the standards set forth by ADEQ. The chemical data in this report is for monitoring purposes only and should not be reported on discharge monitoring reports.


MAGNOLIA WASTEWATER SYSTEM

City of Magnolia Big Creek WWTP
P.O. Box 666
Magnolia, AR 71754-0666
Permit # AR0043613
AFIN # 1400059



RETURN RECEIPT
REQUESTED

CERTIFIED MAIL®



7015 0640 0004 2331 7023

ADEQ
Water Division
NPDES Enforcement Section
5301 North Shore Drive
North Little Rock, AR 72118-5317

721185317 7015



U.S. POSTAGE
MAGNOLIA, AR
JUL 20 15
AMOUNT
\$6.96
R2305E123557-21