

NON-COMPLIANCE REPORT

January 1, 2015

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 North Shore Drive  
North Little Rock, AR 72118

**RE: NPDES Permit No. AR0043613 AFIN No. 14-00059 Discharge Number: 001**

**Facility: City of Magnolia-Big Creek WWTP**

**Physical Address: 72 Columbia Road 300 Magnolia, AR 71753**

**Mailing Address: P.O. Box 666 Magnolia, AR 71754-0666**

**Contact: Russell Thomas Phone: 870-234-2955 Fax: 870-234-2203**


**Email: [mwws@sbcglobal.net](mailto:mwws@sbcglobal.net)**

Date of Non-compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
01/27/2015	CBOD	341 pounds		209 pounds
01/27/15	CBOD		15.20 mg/L	15.00 mg/L

**We feel like this problem was due to: Toxicity sludge from Magnolia Water Plant.**

**Time estimated that it will take to correct problem: Cannot correct the problem as long as the Water Plant discharges the blow down, backwash water and sludge is being sent to us.**

Sincerely,



Russell W. Thomas

02/19/2015

Date

## Sanitary Sewer Overflow (SSO) Monthly Tabular Report

Facility Name: Magnolia, City of Big Creek WWTP NPDES Permit No.: AR0043613

Monitoring Period (Month/Year): 01 / 2015

AFIN: 14-00059

Month      Year

No Sanitary Sewer Overflows This Monitoring Period

### Summary Report Code Descriptions

Cause(s) of SSO		Environmental Impact	Action(s) Taken	Ultimate Discharge Locat
CO-Construction	D-Debris	NEAH-No Evid. of Adverse Health/Environmental Impact	WO-Work Order	CR-Creek/Stream/River (speci
E-Equipment Failure	G-Grease	OEEI-Observed or Evidence of Environmental Impact	EC-Environmental Cleanup	DI-Ditch
LF-Line Failure	R-Rainfall	OEHC-Observed or Evidence of Human Contact	HC-Hydro Cleaned	DR-Drop Inlet
RG-Roots / Grease	RO-Roots	EFK-Evidence of Fish Kill	HR-Hand Rodded	GR-Ground Surface
V-Vandalism			EN-Referred to Engineering	PA-Paved Area
			PN-Public Notification	CB-Contained in Building

Location.	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Ultimate Dischar Location

Signature ► Russell W. Brown


Date ► 02/19/2015

**Signature of Cognizant Official (sign above)-----Date above (Month/ Day/ Year)-----For ADEQ Staff Use (below)**

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Mail to: **ADEQ Water Division P.O. Box 8913 Little Rock, AR 72219-8913** Mail NO later than the 25<sup>th</sup>. of the month following the monitoring period. You should send in the same envelope with the DMR.

City of Magnolia Big Creek WWTP  
P.O. Box 666  
Magnolia, AR 71754-0666  
Permit # AR0043613  
AFIN # 14-00059



LITTLE ROCK AR

25 FEB 2015 PM



NPDES Enforcement Section  
Water Division  
ADEQ  
5301 North Shore Dr.  
North Little Rock, AR 72118-5317

72118531799

