

NON-COMPLIANCE REPORT

October 23, 2012

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 North Shore Drive
North Little Rock, AR 72118

RE: NPDES Permit No. AR0043613 **AFIN No.** 14-00059 **Discharge Number:** 001

Facility: City of Magnolia-Big Creek WWTP

Physical Address: 72 Columbia Road 300 Magnolia, AR 71753

Mailing Address: P.O. Box 666 Magnolia, AR 71754-0666

Contact: Russell Thomas **Phone:** 870-234-2955 **Fax:** 870-234-2203

Email: mwws@sbcglobal.net

Date of Non-compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
09/25/2012	Fecal Coli form		7 day Geo 660	200/400

We feel like this problem was due to:

Filter floss on chlorine feed header stopped up. Cl2 quit feeding.


We plan on correcting the problem in this manner:

By changing filter floss every time we change cylinders.

Time estimated that it will take to correct problem:

Immediately.

Sincerely



Russell W. Thomas

10/23/2012

Date

Sanitary Sewer Overflow (SSO) Monthly Tabular Report

Facility Name: Magnolia, City of

NPDES Permit No.: AR0043613

Monitoring Period (Month/Year): 09 / 2012
Month Year

AFIN: 14-00059

No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions

Cause(s) of SSO		Environmental Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evid. of Adverse Health/Environmental Impact	WO-Work Order	CR-Creek/Stream/River (specify)
E-Equipment Failure	G-Grease	OEEI-Observed or Evidence of Environmental Impact	EC-Environmental Cleanup	DI-Ditch
LF-Line Failure	R-Rainfall	OEHC-Observed or Evidence of Human Contact	HC-Hydro Cleaned	DR-Drop Inlet
RG-Roots / Grease	RO-Roots	EFK-Evidence of Fish Kill	HR-Hand Rodded	GR-Ground Surface
V-Vandalism			EN-Referred to Engineering	PA-Paved Area
			PN-Public Notification	CB-Contained in Building

Location.	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Ultimate Discharge Location

Signature ► Russell White

Date ► 10/ 23 / 2012


Signature of Cognizant Official (sign above)-----Date above (Month/ Day/ Year)-----For ADEQ Staff Use (below)

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."


Mail to: **ADEQ Water Division P.O. Box 8913 Little Rock, AR 72219-8913** Mail NO later than the 25th of the month following the monitoring period. You should send in the same envelope with the DMR.

City of Magnolia
Big Creek WWTP
P.O. Box 666
Magnolia, AR 71754
Permit # AR0043613 AFIN # 14-00059

M



LITTLE ROCK AR 722
23 OCT 2012 PM 4 1



NPDES Enforcement Section
Water Division
Arkansas Department of Environmental Quality
5301 N. Shore Dr.
North Little Rock, Arkansas 72118-5317

72118531799

