

NON-COMPLIANCE REPORT

August 14, 2012

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

**RE: NPDES Permit No. AR0043613 AFIN No. 14-00059 Discharge Number: 001**

**Facility: City of Magnolia-Big Creek WWTP**

**Physical Address: 72 Columbia Road 300 Magnolia, AR 71753**

**Mailing Address: P.O. Box 666 Magnolia, AR 71754-0666**

**Contact: Russell Thomas Phone: 870-234-2955 Fax: 870-234-2203**

**Email: [mwws@sbcglobal.net](mailto:mwws@sbcglobal.net)**

Date of Non-compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
07/03/2012	Fecal Coliform		550	200/400
07/31/2012	Fecal Coliform		344	200/400

**We feel like this problem was due to:**

Don't Know at this time

**We plan on correcting the problem in this manner:**


Requested on July 23<sup>rd</sup> 2012 that Mike Coston (technician) with Instrument & Supply Company, 1-501-321-5532, to come down and go through the programming of the Control panel of the Chemical feed system.

Mr. Coston was here to check programming on Thursday August 3<sup>rd</sup> 2012. At that time he made some adjustments to the programming.

**Time estimated that it will take to correct problem:**

Took corrective action as soon as we received test results.

Sincerely

  
Russell W. Thomas

08/14/2012  
Date