

NON-COMPLIANCE REPORT

July 20, 2012

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No. AR0043613 AFIN No. 14-00059 Discharge Number: 001

Facility: City of Magnolia-Big Creek WWTP

Physical Address: 72 Columbia Road 300 Magnolia, AR 71753

Mailing Address: P.O. Box 666 Magnolia, AR 71754-0666

Contact: Russell Thomas Phone: 870-234-2955 Fax: 870-234-2203

Email: mwws@sbcglobal.net

Date of Non-compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
06/05/2012	Fecal Coliform		800	200/400

We feel like this problem was due to:

Opened equalization pond back into plant, dosage level to low .

We plan on correcting the problem in this manner:

We have raised the dosage level up.

Will get with the lab and will have them contact us as soon a test come off

Time estimated that it will take to correct problem:

Took corrective action as soon as we received test results.

Sincerely



Russell W. Thomas

07/20/2012

Date