

NON-COMPLIANCE REPORT

June 21, 2013

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 North Shore Drive
North Little Rock, AR 72118

RE: NPDES Permit No. AR0043613 AFIN No. 14-00059 Discharge Number: 001

Facility: City of Magnolia-Big Creek WWTP

Physical Address: 72 Columbia Road 300 Magnolia, AR 71753

Mailing Address: P.O. Box 666 Magnolia, AR 71754-0666

Contact: Russell Thomas Phone: 870-234-2955 Fax: 870-234-2203

Email: mwws@sbcglobal.net

Date of Non-compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
Nitrogen, ammonia Total (as N)	Loading Mo avg 7 DA AVG	146.20 #	11.87 mg/l 14.60 mg/l	50 LBs 2.4 mg/l 6.1 mg/l
BOD	Loading Mo avg. 7 DA AVG	275 #	20.7 mg/l 50.4 mg/l	209 10 mg/l 15 mg/l

We feel like this problem was due to:

The City owned Water treatment plant discharging backwash water and sludge to our system.


We plan on correcting the problem in this manner:

We had a PPS run on our Influent when we caught it coming in to our plant. Collecting samples for analysis on the water treatment plant discharge.

Time estimated that it will take to correct problem:

Immediately.

Sincerely


Russell W. Thomas

06/21/2013
Date