

Sanitary Sewer Overflow (SSO) Monthly Tabular Report

Facility Name: Magnolia, City of

NPDES Permit No.: AR0043613

Monitoring Period (Month/Year): 03 / 2013
Month Year


AFIN: 14-00059

No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions

Cause(s) of SSO		Environmental Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evid. of Adverse Health/Environmental Impact	WO-Work Order	CR-Creek/Stream/River (specify)
E-Equipment Failure	G-Grease	OEI-Observed or Evidence of Environmental Impact	EC-Environmental Cleanup	DI-Ditch
LF-Line Failure	R-Rainfall	OEHC-Observed or Evidence of Human Contact	HC-Hydro Cleaned	DR-Drop Inlet
RG-Roots / Grease	RO-Roots	EFK-Evidence of Fish Kill	HR-Hand Rodded	GR-Ground Surface
V-Vandalism			EN-Referred to Engineering	PA-Paved Area
			PN-Public Notification	CB-Contained in Building

Location.	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Ultimate Discharge Location
913 BurntBridge Rd.	MH-199B	05/14/2013	05/14/2013	100-200	grease	NEAH	Jet-Vac, HC	PA, GR

Signature ► 

Date ► 05/21/2013

Signature of Cognizant Official (sign above)-----Date above (Month/ Day/ Year)-----For ADEQ Staff Use (below)

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Mail to: ADEQ Water Division P.O. Box 8913 Little Rock, AR 72219-8913 Mail NO later than the 25th of the month following the monitoring period. You should send in the same envelope with the DMR.

City of Magnolia


Big Creek WWTP

P.O. Box 666

Magnolia, AR 71754


Permit # AR0043613 AFIN # 14-00059

M



LITTLE ROCK AR 72118

26 JUN 2013 PM 3



NPDES Enforcement Section
Water Division
ADEQ
5301 N. Shore Dr.
North Little Rock, Arkansas 72118-5317

72118531799

