

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

**RE: NPDES Permit No:** AR0044016      **Discharge Number:** A - 001-Monthly

**Facility:** Ark. Dept of Correction-NCU-Izard County Facility

**Address:** Ark State Hwy 5 & NE on CR 46 1.25 MI

**City:** Calico Rock      **State:** AR      **Zip:** 72519

**Contact:** Robert Leggett      **Phone:** 870-267-6669

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
August, 2022	NO2+NO3		12.0 mg/l daily max	10 mg/l daily max limit
August, 2022	Fc		1040 cfu/100mls	200 cfu/100mls 7 day geo limit

We feel this problem was due to:

Tanks need to be cleaned due to excessive algae.

We plan on correcting the problem in this manner:

Tanks drained, pressure washed and chlorine tablets added to water on September 27, 2022.

Time estimated that it will take to correct the problem/s:

Corrected to normal levels on or before October 19, 2022.

Sincerely,

  
Authorized Signature

9/28/2022  
Date