

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0044016 Discharge Number: A - 001-Monthly

Facility: ADC- NCU Iazard Co Unit

Address: Rt. 5, Hwy. 5N

City: Calico Rock

State: AR

Zip: 72519

Contact: Robert Leggett

Phone: 870-267-6669

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
December, 2022	Fc		550 MPN/100 mls	200 MPN/100mls 7day limit
December, 2022	DO		4.01 mg/l	5.0 mg/l Inst. Min

We feel this problem was due to:

DO Probe currently nonfunctioning.

We plan on correcting the problem in this manner:

A new DO Probe was ordered on October 27, 2022.

Time estimated that it will take to correct the problem/s:

DO Probe shipping from warehouse second week of February 2023. Issue should be resolved 30 days after DO Probe installed. Estimated Correction date March 15, 2023.

Sincerely,


Authorized Signature

1/20/2023
Date