

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0044016

Discharge Number: A - 001-Monthly

Facility: ADC- NCU Iazard Co Unit

Address: Rt. 5, Hwy. 5N

City: Calico Rock

State: AR

Zip: 72519

Contact: Robert Leggett

Phone: 870-267-6669

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
12/29/2023	Nitrate+Nitrite	19.25lbs/D Day Max	21.2mg/L Max	7.5lbs/D Day Max & 10.0mg/L Max

We feel this problem was due to:

Aeration producing too much oxygen.

We plan on correcting the problem in this manner:

Reducing the aeration.

Time estimated that it will take to correct the problem/s:

30 days from January 26, 2024.

Sincerely,

Authorized Signature

Date