

NON-COMPLIANCE NOTIFICATION

DMR Monitoring Period 5/01/2018 - 5/31/2018

FROM: ADC-NCU-Izard County Facility
RT 5, HWY 5 N
Calico Rock, AR 72519

DATE: 6/15/2018

PERMIT #: AR0044016

TO: NPDES Enforcement
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The Dissolved Oxygen was reported below the Instantaneous Minimum permit limit.

3. CAUSE FOR NON-COMPLIANCE:

Main Aerator WAS DOWN due TO repair to Main Shaft and Bearings.

4. DURATION OF NON-COMPLIANCE:

The Non-Compliance Description above took place on May 2nd, 2018.

5. CORRECTIVE ACTION BEING TAKEN:

Aerator is back UP and in operation.

SIGNATURE: 