

## NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0044016 Discharge Number: A - 001-Monthly

Facility: ADC- NCU Iazard Co Unit

Address: Rt. 5, Hwy. 5N

City: Calico Rock

State: AR

Zip: 72519

Contact: Robert Leggett

Phone: 870-267-6669

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
1/9/2023	TSS	24.01lb/d MO Avg	21.50mg/L Mo Avg	11.3lb/d Mo Avg -- 15.0mg/L Mo Avg
1/9/2023	TSS	24.01lb/d Day Max		16.9lb/d Day Max

We feel this problem was due to:

Dissolved Oxygen Probe is not functioning and regulating the clarifier properly.

We plan on correcting the problem in this manner:

Dissolved Oxygen Probe has been delayed in shipping. Expected to be delivered end of March 2023. Possibly installed April 10, 2023.

Time estimated that it will take to correct the problem/s:

Thirty days after Installation.

Sincerely,

  
Authorized Signature

2-24-23  
Date