

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0044016 Discharge Number: A - 001-Monthly

Facility: Ark. Dept of Correction-NCU-Izard County Facility

Address: Ark State Hwy 5 & NE on CR 46 1.25 MI

City: Calico Rock

State: AR

Zip: 72519

Contact: Robert Leggett

Phone: 870-267-6669

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
June, 2022	DO		2.9 mg/l	5.0 mg/l Min. limit
June, 2022	NH3	3.4 lb/d Daily Max	8.0 mg/l Daily Max	2.9 lb/d Max & 3.9 mg/l Max liimit
June, 2022	Fc		1900 cfu/100mls	200 cfu/100mls 7 day geo limit
June, 2022	CBOD		13.8 mg/l Mo. Avg	10 mg/l Mo. Avg limit

We feel this problem was due to:

Aerator not working.

We plan on correcting the problem in this manner:

Aerator installed June 30, 2022.

Time estimated that it will take to correct the problem/s:

30 days for the aerator to correct the issues.

Sincerely,



7/26/2022

Authorized Signature

Date