

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0044016

Discharge Number: A - 001-Monthly

Facility: ADC- NCU IZARD Co Unit

Address: Rt. 5, Hwy. 5N

City: Calico Rock

State: AR

Zip: 72519

Contact: Chris Ashcraft

Phone:

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
6/24/2024	Nitrate+Nitrite MAX		12.8mg/L	10.0mg/L
6/24/2024	D.O. Inst. Min		4.64mg/L	5.1mg/L

We feel this problem was due to:

Float & timers needed adjusted from installation.

We plan on correcting the problem in this manner:

Float & timers adjusted June 20, 2024 by Crawford Electric.

Time estimated that it will take to correct the problem/s:

60 days from adjustment, August 20, 2024.

Sincerely,

Ronald Riley
Authorized Signature

7-22-2024
Date