

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0044016

Discharge Number: A - 001-Monthly

Facility: ADC- NCU Iazard Co Unit

Address: Rt. 5, Hwy. 5N

City: Calico Rock

State: AR

Zip: 72519

Contact: Robert Leggett

Phone: 870-267-6669

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/22/2023	Dissolved Oxygen		2.84mg/L INS Min	5.1mg/L INS Min
5/22/2023	TSS	14.63lb/D MO Avg	18.5mg/L Mo Avg	15.0mg/L Mo Avg & 11.3lb/D MO Avg
5/22/2023	Nitrate+Nitrite	14.37lbs/D Day Max	11.6mg/L Max	7.5lbs/D & 10.0mg/L Day Max
5/22/2023	Fecal		>2420 30 Day Geo & >2420 7 Day Geo	200 30 Day Geo & 200 7 Day Geo

We feel this problem was due to:

Sample taken from the wrong location in the system.

We plan on correcting the problem in this manner:

Area for testing has been designated.

Time estimated that it will take to correct the problem/s:

Immediately & has been corrected.

Sincerely,


Authorized Signature

6-28-2023
Date