

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0044016

Discharge Number: A - 001-Monthly

Facility: ADC- NCU IZARD Co Unit

Address: Rt. 5, Hwy. 5N

City: Calico Rock

State: AR

Zip: 72519

Contact: Robert Leggett

Phone: 870-267-6669

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
11/7/2023	Nitrate+Nitrite	18.40lbs/D Day Max	24mg/L Max	7.5lbs/D Day Max & 10.0mg/L Max

We feel this problem was due to:

Pump and UV Light's not functioning properly.

We plan on correcting the problem in this manner:

Replaced pump & nonworking UV Lights 11-3-2023.

Time estimated that it will take to correct the problem/s:

Problem corrected 11-14-2023.

Sincerely,

  
Authorized Signature

12/21/23  
Date