

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0044016

Discharge Number: A - 001-Monthly

Facility: ADC- NCU Iazard Co Unit

Address: Rt. 5, Hwy. 5N

City: Calico Rock

State: AR

Zip: 72519

Contact: Robert Leggett

Phone: 870-267-6669

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
9/25/2023	Nitrate+Nitrite	9.77lbs/D Day Max		7.5lbs/D Day Max

We feel this problem was due to:

Raw pump is down New pump is order

We plan on correcting the problem in this manner:

New pump ordered

Time estimated that it will take to correct the problem/s:

10 - 31 - 23

Sincerely,



Authorized Signature

10-25-23

Date