

NON-COMPLIANCE NOTIFICATION

FROM: ADC-NCU-Izard County Facility
RT 5, HWY 5 N
Calico Rock, AR 72519

DATE: 5/12/2015

PERMIT #: AR0044016

TO: NPDES Enforcement
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The TSS exceeded Daily Max Loading and Concentration values.
The FC exceeded the 7 Day GEO value.
The Ammonia exceeded the Daily Max Loading value.

3. CAUSE FOR NON-COMPLIANCE:

*weather. The temp. was coming warm one day cold the next
Rained everyday*

4. DURATION OF NON-COMPLIANCE:

The non-compliance descriptions listed above took place on April 1st, 2015
when the sample was collected.

5. CORRECTIVE ACTION BEING TAKEN:

*wasted to get rid of water & solids cleaned up lights
back in compliance*


SIGNATURE: _____

D. J. [Signature]

TRAVIS ADAIR
FISCAL SUPPORT ANALYST
ARKANSAS DEPT. OF CORRECTION
7800 CORRECTION CIRCLE
PINE BLUFF, AR 71603

720 721 72114S S1-14


PSRT FIRST-CLASS MAIL
US POSTAGE PAID
Little Rock, AR
PERMIT # 700



4068150603-131242

RETURN SERVICE REQUESTED

72118



Jacqueline Trotta
Enforcement Analyst
Water Division
Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, AR 72118