

NON-COMPLIANCE NOTIFICATION

FROM: ADC-NCU-Izard County Facility
RT 5, HWY 5 N
Calico Rock, AR 72519

DATE: 7/15/2015

PERMIT #: AR0044016

TO: NPDES Enforcement
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The Nitrogen, Nitrate total exceeded the Daily Max Loading value.

3. CAUSE FOR NON-COMPLIANCE:

4. DURATION OF NON-COMPLIANCE:

The non-compliance descriptions listed above took place on June 3, 2015 when the sample was collected.


5. CORRECTIVE ACTION BEING TAKEN:

Added oxygen to the aeration tank using aeration pumps to correct the lack of oxygen.

SIGNATURE:



TRAVIS ADAIR
FISCAL SUPPORT ANALYST
ARKANSAS DEPT. OF CORRECTION
7800 CORRECTION CIRCLE
PINE BLUFF, AR 71603



Jacqueline Trotta
Enforcement Analyst
Water Division
Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, AR 72118